UALITY. VALUE. ECONOMIC GROWTH.							
WWW.MIAMIDADE.GOV/WATER	MIAMI-DADE COUNTY						



Sheet Number: 6.0

Product Specifications

Miami-Dade Water & Sewer Department Address: 3071 SW 38th Ave, Miami, FL 33146 Phone: (305) 665-7477

Tapping Sleeves



Minimum Standards

- AWWA C110, C111
- ANSI 21.10, A21.11
- MDWASD Specifications: Sections 15100, 15102, 15120

Other Requirements

- Construction: Cast Iron, Stainless Steel AISI 316/316L
- Minimum working pressure: 150 PSI

Applications

Water and Sewer

PRE	-APPROVED MANUFACTURER	Issue Date:		
1)	American Flow Control	4)	PowerSeal	4/4/2016
2)	Ford	5)	Tyler Union	
3)	JCM	6)	Total Piping Solutions	
,		,	1 3	Revised Date: 9/9/016

APPROVED PRODU	CTS /						
PIPE SIZE		MANUFACTURER		Model	MODEL		
DUCTILE IRON							
4" - 24"		American Flow Co	ontrol	Series	Series 2800 (DI)		
6" - 12"		Tyler Union		25U Co	mpact DI MJ		
STAINLESS STEEL							
14" - 24"		Ford		FTSS-> outlet)	xxx-MJ-Q style (with SS Mechanical Joint		
4" - 12"		Ford		FTSS-x	FTSS-xxxx-MJ-Q style (with Mechanical Joint outlet)		
4" - 24"		JCM		JCM 64	JCM 6439 & 6459 (SS)		
4" - 12"		PowerSeal		3490A	3490AS (SS)		
4" - 30"		PowerSeal		3490M	3490MJ-SST316		
4" - 12" Tota		Total Piping Solutions		Extend	Extended Range 316 SS Tapping Sleeve		
SIZE FURNISHED:							
□ 4	. "		12"		20"		
	3"		14"		24"		
□ 8	3"		16"		30"		
□ 1	10"		18"		Other		
COMMENTS:							

Approved by: David Vazquez, PE

Title: Specifications Manager